GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026080604922 **Dated: 23-10-2026**

SHORTCOMING(S)

With reference to your application ID **52026080604922** dated **23-10-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **RAJLOK BUILDING** at **24, Nehru Place, New Delhi-110019.** from fire safety point of view in presence of **Sh Abhishek Bansal** on dated **01/10/2026** During the course of inspection following observations were made:-

1.Firs Aid hose reels are provided but not functional.
2.Type of detectors heat and smoke provided but not functional.
3.MOEFA provided but not functional.
4.Public address system found removed.
5.Terrace level pump discharge of 900 LPM provided but not functional.
6.Exit signage found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-
1. ABHISHEK Bansal , HOUSE NO C-10/3, VASANT VIHAR -1 , SOUTH WEST , NEW DELHI, 110057
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.