GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026081305023 **Dated: 19-10-2026**

SHORTCOMING(S)

With reference to your application ID **52026081305023** dated **19-10-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Govt. Sarvodaya Co-ed Vidyalaya** at **Wazirpur Village, Delhi - 110052.** from fire safety point of view in presence of **Dr. Suman Sharma, Principal** on dated **05/10/2026** During the course of inspection following observations were made:-

1. Fire Extinguishers provided but some found non functional.
2. First aid hose reel provided but not functional and missing some nozzle.
3. Terrace fire pump not on auto start mode.
4. Electric meter and electric panel under the staircase are not permitted as per BBL.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-
1. DR SUMAN SHARMA , SV, WAZIRPUR VILLAGE , WAZIRPUR VILLAGE , DELHI, 110052
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.