GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026091505498 **Dated: 11-11-2026**

SHORTCOMING(S)

With reference to your application ID **52026091505498** dated **11-11-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Mata Nand Kaur Sr. Sec public School** at **Dhansa Village, New Delhi110073** from fire safety point of view in presence of **Rajender Dagar- Principal** on dated **30/10/2026** During the course of inspection following observations were made:-

1.First Aid Hose Reel provided but not functional.
2.Fire pumps provided but not functional

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. RAJ DAGAR , 20, 36/13, VPO DHANSA, NEW DELHI, 110073
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.