C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2026/School/WZ/ 85 Dated: 30/06/2026

FIRE SAFETY CERTIFICATE

Certified that the Nav Jyoti Public School located at J-33,34, Prem Nagar -III, Kirari Suleman Nagar, Delhi-110085, comprised of Ground & 02 Upper Floors owned/ occupied by the Nav Jyoti Public School has already been issued FSC by this department vide letter No. F6/DFS.MS/School/WZ/2023/456 dated 04/07/2023. The premises was inspected by the officer concerned of this department on 15/06/2026 in the presence of Sh. Ashwani (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy "Group B Educational (School)" with effect from 30/06/2026 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/06/2026 at New Delhi by

29/06/26
(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Deputy Director of Education, MCD, Sector-5, Rohini Zone, Delhi – 110085.
2. The Principal, Nav Jyoti Public School located at J-33,34, Prem Nagar -III, Kirari Suleman Nagar, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Nav Jyoti Public School, J-33, 34, Prem Nagar-III, Kirari Suleman Nagar, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of Building : Ground & 02 upper floors
5. Details of Previous FSC : F6/DFS.MS/School/WZ/2023/456 dated 04/07/2023
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 15/06/2026
8. Name of Inspecting Officer : ADO (Kirari)
9. Name and designation of officers From the building side : Mr. Ashwani (Manager)
10. Year of Construction : 2011
11. Applicant's letter No. : Application No-52026060203338

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements As Per Rules 35 (6)	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	6.0m	6.0m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50m	1.70m & 1.60m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	1.50m	1.80m	MR
	f. Door Size	01m	01m	MR
3.	**Compartmentation**			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilated	MR
5.	**Fire Extinguishers**			
	• Total numbers	08nos.	08nos.	MR

6.	**First-Aid Hose Reels**				
	• Total numbers on each floor	01		Provided	MR
	• Length of hose reel hose	30m		Provided	MR
	• Nozzle diameter	5mm		Provided	MR
7.	**Automatic fire detection and alarming system**				
	• Type of detectors	NA		NA	NA
	• Location of Main Panel	NA		NA	NA
	• Location of Repeater Panel	NA		NA	NA
	• Alternate source of power	NA		NA	NA
	• Hooters' Location	NA		NA	NA
		NA		NA	NA
8.	**MOEFA**	NA		NA	NA
9.	**Public Address System**				
10.	**Automatic Sprinkler System**				
	• Basement	NA		NA	NA
	• Ground & Upper Floors	NA		NA	NA
	• Sprinkler above false ceiling	NA		NA	NA
11.	**Internal Hydrants**				
	• Size of riser/down-comer	NA		NA	NA
	• Number of hydrants per floor	NA		NA	NA
	• Hose Box	NA		NA	NA
12.	**Yard Hydrants**				
	• Total number of hydrants	NA		NA	NA
	• Hose Box	NA		NA	NA
13.	**Pumping Arrangements**				
	• Ground Level	NA		NA	NA
	➢ Discharge of main Pump	NA		NA	NA
	➢ Head of Main pump	NA		NA	NA
	➢ Number of main pumps	NA		NA	NA
	➢ Jockey Pump out put	NA		NA	NA
	➢ Jockey pump head	NA		NA	NA
	➢ Standby Pump out put	NA		NA	NA
	➢ Standby Pump Head	NA		NA	NA
	➢ Auto Starting/Manual Stopping	NA		NA	NA
	➢ Pump House Access	NA		NA	NA
	• Terrace level				
	➢ Discharge of pump	450 LPM		Provided	MR
	➢ Head of pump	40m		Provided	MR
					MR

14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltr	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	**Standby power supply**	NA	NA	NA
18.	**Refuge Area.**			
	➢ Total Area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	**Fire Control Room**			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS.MS/School/WZ/2023/456 dated 04/07/2023, **is recommended for renewal** under rule 37 of the Delhi Fire Service rules 2010.

16/06/2026

Signature of the Inspecting Officer
Name:- C.L. Meena
Designation ADO(Kirari)

DO/NW 18/6

Dy CFO/WZ

CFO (WZ)

18/06/2026

18/06/26

– Nil –

F.T. please.

22/06/26

ADO (Kisarsi)

As approved, F.T. letter is put up for your Signature please –

23/06/2026

CFO(HZ)

29/06/26

F.P. wing