GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/Instt./2026/NDZ/91 Dated: 04/07/2026

FIRE SAFETY CERTIFICATE

Certified that the **New Millennium Education Society** located at Plot No. 16 X, Karkardooma Institutional Area, Delhi-110092, comprised of basement, ground plus five upper floors owned/occupied by New Millennium Education Society was issued FSC vide letter No.: F.6/DFS/MS/School/2023/NDZ/100 dated 22/02/2023. The premise was re-inspected by the officer concerned of this department on 22/06/2026 in the presence of Mr. Vineet Aggarwal and observed that all the fire prevention and fire safety arrangements provided in the accordance with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the premises is fit for occupancy class **"Educational"(Group-B)** as above with effect from 04/07/2026 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....04/07/2026.....at New Delhi by

A17/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFCIER

O/C D.

To:-

The Manager, **New Millennium Education Society** located at Plot No. 16 X, Karkardooma Institutional Area, Delhi-110092

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on **www.dfs.delhigovt.nic.in**

Received by Kailash 9811566290 04/07/25

N/35

1. Name & address of the building : M/s New Millennium Education Society
   Plot No. 16 X, Karkardooma Institutional Area
   Delhi -110092
2. Building is comprised of : Basement, Ground plus Five upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2023/NDZ/100 dt 22/02/2023
6. Fire Safety directive letter No. : F.6/DFS/MS/BP/2012/3046 dated 22/08/2012
7. Date of Inspection : 22/06/2026
8. Name of the Inspecting officers : Deepak Kumar, ADO (Shahdara)
9. Name and designation of Officer from the building side : Mr. Vineet Aggarwal
10. Year of Construction : 2004 & 2012 (addition/alteration)
11. Applicant's letter No : 52026050202652 dated 01/06/2026

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	12 mtr.	24 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	06 mtr	06 mtr.	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	03 nos.	MR
	B. Width of Staircases			
	• Upper floor	1.50 mtr	1.50 mtr	MR
	• Basement	1.50 mtr	1.50 mtr	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of Continuous Staircases to Terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	1.50 mtr.	2.40 mtr.	MR
	f. Door Size	1.20 mtr.	1.20 mtr.	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	02 hrs	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	Required	Provided	MR
04	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Ventilated	MR
05.	Fire Extinguishers.			
	• Total numbers	20 nos.	25 nos.	MR
	• Types	ABC /CO_2	ABC /CO_2	MR
	• IS marking	ISI marked	ISI marked	MR

N/96

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	Provided	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos	01 nos	MR
	• Hose box	01 nos	01 nos	MR
12	Yard Hydrants.			
	• Total number of hydrants	03 nos	04 nos	MR
	• Hose box	03 nos	04 nos	MR
13	Pumping Arrangements.			
	➢ Ground Level			
	• Discharge of main pump	1620 lpm	1620 lpm	MR
	• Head of main pump	70 mtr	70 mtr	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	70 mtr	70 mtr	MR
	• Standby pump out put	1620 lpm	1620 lpm	MR
	• Standby pump head	70 mtr	70 mtr	MR
	• Auto starting/manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➢ Terrace Level			
	• Discharge of pump	900 Lpm.	900 Lpm.	MR
	• Head of the pump	45 M	45 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 ltr	50,000 ltr	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	25,000 Ltr.	25,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A

N/37

17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	Required	Provided	MR

The fire protection system provided in the building were tested, checked and found functional at the time of inspection. The shortcomings have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC issued vide letter no. F.6/DFS/MS/School/2023/NDZ/100 dated 22/02/2023 **renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.**

29/06/2026.

Signature of the Inspecting Officer
Name :-Deepak Kumar
Designation :-ADO (shahdara)

DO(ED)
29/06/26

CFO (ECN)
29/6/26

Principal Director

CFO to issue.
3/7

CFO (ECN)
3/7/26

ADO Ed.

Sir, F.T. letter is put up for kind signature pl.
1/7/2026