GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/ 88 Dated: - 02/07/2026

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya/Govt. Boys Sr. Sec. School, Located at Avantika, Sectoor-1, Rohini, Delhi-110085, comprised of 03 Blocks, 02 Blocks – Ground + 01 Upper Floor and 01 Block – Ground + 03 Upper Floors only owned/occupied by Govt. Sarvodaya Kanya Vidyalaya, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2023/334 dated 18/05/2023. The said premise was re-inspected by the officer concerned of this department on 13/06/2026 in the presence of Ms. Kaur Sandhu (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance NBC (Part-IV)/D.O.E. GNCT of Delhi, Circular No. 3298-3398 dated 01/03/2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 02/07/2026 for a period of three years, in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on 02/07/2026 at New Delhi by.

01/07/26
(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya/Govt. Boys Sr. Sec. School, Located at Avantika, Sectoor-1, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building	Govt. Sarvodaya Kanya Vidyalaya/Govt. Boys Sr. Sec. School, located at Avantika, Sector-1, Rohini, Delhi-110085
2. Type of Occupancy	Educational Building
3. Type of Case	Renewal
4. Composition of building	03 Blocks, Block-1 & 2 = G+01 Upper Floor and Block-3 = G+03 Upper Floors
5. Details of Previous NOC	F6/DFS/MS/School/WZ/2023/334 dated 18/05/2023
6. Fire Safety directives letter No	Nil
7. Date of inspection	13/06/2026
8. Name of Inspecting Officer	Paras Kumar, ADO (Rohini)
9. Name and designation of officers From the building side	Ms. Kaur Sandhu (Principal)
10. Year of Construction	2017
11. Applicant's online application no.	52026060203325

S. No	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 3298-3398 dated 01/03/2011/as per earlier FSC issued dated 18/05/2023	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	BL-1 & 2 = 01 BL-3 = 02	BL-1 & 2 = 01 BL-3 = 03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m	BL-1 = 1.50 m BL-2 = 1.50 m & BL-3 = 1.90 m x 03	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	1.0 m	1.10 m	MR
3.	**Compartmentation**			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	a) Basements	NA	NA	NA
	b) Ground floor	12 a/c per hour	Natural Ventilation	MR

5.	**Fire Extinguishers**				
	a) Total numbers	40 nos.		Provided	MR
	b) Types	ABC/CO2		Provided	MR
	c) IS marking	ISI marked		Provided	MR
6.	**First-Aid Hose Reels**				
	a) Total numbers on each floor	02		03	MR
	b) Length of hose reel hose	30mm		Provided	MR
	c) Nozzle diameter	05 mm		Provided	MR
7.	**Automatic fire detection and alarming system**				
	a) Type of detectors	NA		NA	NA
	b) Location of Main Panel	NA		NA	NA
	c) Location of Repeater Panel	NA		NA	NA
	d) Alternate source of power	NA		NA	NA
	e) Hooters' Location	NA		NA	NA
8.	**MOEFA**	NA		NA	NA
9.	**Public Address System**	NA		NA	NA
10.	**Automatic Sprinkler System**				
	a) Basement	NA		NA	NA
	b) Upper Floors	NA		NA	NA
	c) Sprinkler above false ceiling	NA		NA	NA
11.	**Internal Hydrants**				
	a) Size of riser/down-comer	NA		Provided	NA
	b) Number of hydrants per floor	NA		Provided	NA
	c) Hose Box	NA		01	NA
12.	**Yard Hydrants**				
	a) Total number of hydrants	NA		NA	NA
	b) Hose Box	NA		NA	NA
13.	**Pumping Arrangements**				
	• Ground Level				
	➢ Discharge of main Pump	NA		NA	NA
	➢ Head of Main pump	NA		NA	NA
	➢ Number of main pumps	NA		NA	NA
	➢ Jockey Pump out put	NA		NA	NA
	➢ Jockey pump head	NA		NA	NA
	➢ Standby Pump out put	NA		NA	NA
	➢ Standby Pump Head	NA		NA	NA
	➢ Auto Starting/Manual Stopping	NA		NA	NA
	➢ Pump House Access	NA		NA	NA
	Terrace level				
	➢ Discharge of pump	450 lpm		450 lpm x 02	MR
	➢ Head of the pump	40 m		Provided	MR
	➢ Power Supply	Required		Provided	MR
	➢ Auto Starting of pump	Required		Provided	MR
14.	**Captive Water Storage for fire fighting**				
	• Underground tank capacity	NA		1,00,000 ltrs.	NA
	➢ Draw-off connection	NA		NA	NA
	➢ Fire service inlet	NA		NA	NA
	➢ Access to tank	NA		NA	NA
	• Overhead Tank capacity	10,000 ltrs.		Provided	MR
15.	**Exit Signage.**	Required		Provided	MR

16.	**Provision of Lifts.**			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	**Standby power supply**	NA	NA	NA
18.	**Refuge Area.**			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	**Fire Control Room**			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	NA	NA	NA

The fire protection systems provided in the building were checked and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety required under the rules, the FSC issued vide letter no. F6/DFS/MS/School/WZ/2023/334 dated 18/05/2023 renewal under rule 37 of the Delhi Fire Service Rule 2010 **is recommended**.

16/06/2026

Signature of the Inspecting Officer
Name : - Paras Kumar
Designation : - ADO ~~(RN)~~ Rohini

DO/N/W

1616

Dy CFO/WZ

22/06/2026

CFO (WZ)

Pr. Director

22/06/26

CFO to Sir.

22/06/26

PT is put up for signature please

OPO/Rohini
1/07/2026

EPO/Luz

F. P. wing

Ring
01/07/26