C-58

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/620 Dated: 04/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Hotel Nitya Maharani Guest House, 78841, Plot No. 27, A.K. Road, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026060508212 dated 05/06/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 17/06/2026 in the presence of Sh. Gopal Khanna, Owner and following shortcomings were observed: -

1. Fire Check Door was not provided in basement.
2. Smoke Management System found removed in basement.
3. Public Address System found removed.
4. Domestic connection in overhead water storage tank is not permitted.
5. Further, staircases shall be provided with Hand Railing.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

4/7/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

OIC BP

Copy to: -

1. The Manager, M/s Hotel Nitya Maharani Guest House, 78841, Plot No. 27, A.K. Road, Paharganj, New Delhi - 110055.