GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/662 Dated:- 9/07/2026

To,

The principal,
New Savitri Public School,
A-5, Sainik Enclave, Vikas Nagar,
Uttam Nagar, New Delhi- 110027

Subj.: - Regarding issuance of Fire Safety Certificate in respect of New Savitri Public School at A-5, Sainik Enclave, Vikas Nagar, Uttam Nagar, New Delhi- 110027.

Sir,

Please refer to your letter received on email dated 28/04/2026 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 30/06/2026 in the presence of Sh. Pritam Kumar (Principal) & Sh. Vijay Kumar (Manager) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/School/SZ/2024/211 dated 02/05/2024 (copy enclosed).

During inspection, it has been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, application for issuance of Fire safety Certificate cannot be considered at this stage & rejected.

Encl: as above.

Yours faithfully,

09/07/26

S.K. Dua
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.

c/03

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2024/ 2411 Dated: - 02/05/2024

To,

The Principal,
New Savitri Public School,
A-5, Sainik Enclave, Vikas Nagar,
Uttam Nagar, New Delhi- 110027.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o New Savitri Public School at A-5, Sainik Enclave, Vikas Nagar, Uttam Nagar, New Delhi- 110059.

Sir,

With reference to your letter No. NSPS/2024 dated 26.03.2024, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 03.04.2024 in the presence of Mr. Vijay Kumar (Manager), to check the fire safety arrangements provided in the school building.

During the course of inspection, it was observed that the school building is comprised of ground floor plus three upper floors. Fire safety arrangements such as fire extinguishers found provided in the school building. However, the following shortcomings were observed: -

1. Two staircases having width of 1.20 & 1.0 mts found provided against requirement of two staircase and atleast one staircase having width of 1.50 mts.
2. First aid hose reel 01 Nos. at each floor found not provided.
3. Terrace fire pump capacity of 450 LPM found not provided.
4. Overhead water storage tank capacity of 10,000 lts found not provided.
5. Exit signage and floor marking at fire escape point found not provided.

In view of the above, issuance of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further necessary action in the matter.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054. For information please.