GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2026/SZ/ 62 Dated: 03/03/2026

To,

The Authorized Signatory,
M/s. A-37, Naraina Industrial Area
Phase- 1, New Delhi - 110028..

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s. A-37, Nariana Industria Area Phase- 1, New Delhi - 110028.

Sir,

This is reference to online MCD request ID- 10117712 dated 19.02.2026, on the subject cited above. In this connection it is to inform you that the aforesaid premises have been jointly inspected by the officer concerned of this department with Sh. Shekhar Singh, JE (MCD), on dated 24.02.2026, to check the status of the shortcomings already pointed out by this department vide letter No. F6/DFS/MS/WZ/2025/498 dated 15.10.2025. During the course of inspection, it was observed that the shortcomings are still not fully complied, and following shortcomings are yet not been complied: -

1. Smoke Management system not provided in basement.
2. Overhead water storage tank of 50,000 ltrs found not provided.
3. Pressurization of Lift Shaft not provided.
4. Staircases are not segregated and lift is opening in lift well as lift lobby is not constructed as per approved drawing. Lift car not installed in second lift well is open on all floors affecting compartmentation. Second staircase is not enclosed in basement.

In view of the above shortcomings, the application for issuance of Fire Safety Certificate is rejected. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter.

Yours faithfully

3/3/26
(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to:-
The Dy. Commissioner, MCD, Karol Bagh Zone, Anand Parbat, New Delhi.