c/59

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/2026/SZ/ 178 Dated: 12/05/2026

To
Dr. Diksha Panesar,
Aadhya 9 Multispecialty Hospital,
W-4 West Patel Nagar,
New Delhi-110008.

Sub: **Inspection report from fire safety point of view in r/o Aadhya 9 Multispecialty Hospital, W-4 West Patel Nagar, New Delhi-110008.**

Ref: Office Order No. F.6/DFS/HQ/2026/494 dated 20/03/2026.

Sir,

This is with reference to the office order above regarding inspections of the hospitals building to verify compliance of fire protection measures. In this connection, it is to inform you that the said hospital building was issued notice on Form 'O' (Notice for Entry and Inspection) under section 33 (1) of the Act) by the Nominated Authority of this department and inspected on dated 30/04/2026 in the presence of Dr. Diksha Panisar. The shortcomings observed during the inspection were recorded and issued on Form 'P' (Notice for carrying out the directions of the Nominated Authority, under section 34 (1)/43(2) of the Act. The hospital building was found non-compliant of fire & life safety provisions required under the rules. Shortcomings as given below: -

1. **Horizontal electrical shaft passing from the electric room is not properly sealed.**
2. **DG Pump is non-functional due to tank leakage.**
3. **Terrace area completely covered with the tin shed.**
4. **A kitchen is being operated on the terrace using LPG gas.**
5. **Temporary porta cabins have been made at terrace need to be removed.**

In view of the non-compliant status of the hospital from fire safety point of view. The Fire Safety Certificate of the hospital building issued vide letter No. F6/DFS/MS/Hospital/SZ/2023/567 dated 21/11/2023 shall remain suspended till the compliance of the shortcomings.

Yours faithfully,

14/5/26

A.K Malik
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The MS – Nursing Home, Govt. of NCT of Delhi, DGHS (Nursing Home Cell), 3rd Floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, New Delhi–110092.