GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO.F.6/DFS/MS/C.C/2026/176 Dated: 25/2/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Center, Minto Road,
New Delhi–110002.

Sub: - Reply of application regarding FSC/NOC in r/o **Aakash Educational Services Pvt. Ltd., Located at Property No K-11 & K- 12, South Extn., Part - I, Delhi – 110049.**

Sir,

This has a reference to MCD online ID- 10121686 dated 10/02/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 19/02/2026 in the presence of Sh. Abhay Shrivastav (ROH). During course of inspection, the shortcomings observed are as below: -

1. Width of the staircases in basements are not provided as per UBBL 2016.
2. Width of the class room door is not provided as per clause 7.23.2 (e) UBBL 2016.
3. Fire Check door is not provided.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

M. K. Chattopadhyay
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Abhay Shrivastav (ROH), Aakash Educational Services Pvt. Ltd., Located at Property No K-11 & K- 12, South Extn., Part - I, Delhi – 110049.