C13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2026/NZ/ 927 Dated: 12/11/2026

To,

The Commissioner,
Municipal Corporation of Delhi, HQ,
Minto Road Civic Center,
New Delhi-110002

Sub: -Regarding issuance of Fire Safety Certificate in respect of M/s Aam Restro Private Limited located at Property No. E-980, Upper Ground Floor and First Floor, Saraswati Vihar, Pitampura, Delhi- 110034.

Sir,

This has reference to online application received through MCD online application no 2026082410665 dated 05/09/2026 on the subject cited above. In this connection, it is to inform you that the above said assembly building was inspected by the officer concerned of this department on 30/10/2026 to see the compliance of requisite fire safety measures. Sh. Naresh was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Width of alternate staircase at first floor found 0.75 m against the required width of 1.5 m and both the staircases shall reaches up to the terrace.
2. Door width at first floor found 1.5 m & 0.75 m against the requirement of 1.5 m each.
3. Fire check door found not provided.
4. First aid hose reel found provided but not functional.
5. MOEFA found not provided.
6. Internal hydrant found provided but not functional.
7. Terrace level pump found provided but not functional.
8. Overhead water storage tank of 5000 Ltrs capacity found provided against the required capacity of 20,000 Ltrs.
9. Inspection ladder found not provided.
10. Exit signage's not provided.

In view of above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

M.K. Chattopadhyay
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Mr. Aman Gupta, M/s Aam Restro Private Limited located at Property No. E-980, Upper Ground Floor and First Floor, Saraswati Vihar, Pitampura, Delhi- 110034.
2. MCD Portal ID No. 2026082410665.