C-65

FORM 'H' : FORM FOR ISSSUNG FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/EH/2026/NDZ/ 691 Dated: 19/08/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s AAM Restro Private Limited located at Plot No.6, Upper Ground Floor, Hargobind Enclave, Karkardooma, Delhi-110092, comprising of Basement, Stilt, Ground plus upper floor but restaurant is running ground floor only owned/occupied by M/s AAM Restro Private Limited was inspected by the officer concerned of this department on 27/07/2026 in the presence of Sh. Aman Gupta, Owner and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy class "**Assembly" Group 'D' (Ground floor only)** with effect from 19/08/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Conditions Mentioned Below.

Issued on.....19/08/2026.....at New Delhi by.

19/8/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFCIER

To, o/c R.

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. Sh. Aman Gupta, Owner, M/s AAM Restro Private Limited located at Plot No.6, Upper Ground Floor, Hargobind Enclave, Karkardooma, Delhi-110092

   MCD ID No. **2026070809632**

Conditions for the validity of Fire Safety Certificate:-

1. FSC is valid for ground floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form `J` [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/22

INSPECTION REPORT

1. Name & address of the building : M/s AAM Restro Private Limited
   Plot No.6, Upper Ground Floor, Hargobind Enclave, Karkardooma, Delhi-110092
2. Building is comprised of : Basement, Stilt, Ground plus three upper floors but restaurant is running at Ground Floor only
   Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New
4. Details of Previous NOC letter : Nil
5. Fire Safety directive letter No : NBC Part IV
6. Date of Inspection : 27/07/2026
7. Name of the Inspecting officers : Deepak Kumar, ADO (Shd.)
8. Name and designation of Officer from the building side : Sh. Aman Gupta, Owner
9. Year of Construction : 2004
10. Applicant's letter No 2026070809632 dated 08/07/2026

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirements	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	06 m	12 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	b. Width of Staircases			
	• Upper Floor	1.50 mtr	1.50 mtr & 02 mtr	MR
	• Basement	N/A	1.50 mtr & 02 mtr	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	01 no.	N/A
	e. width of Corridor	N/A	N/A	N/A
	f. No. of doors	02 nos.	02 nos.	MR
	g. Door Size	1.50 mtr	1.50 mtr & 1.50 mtr	MR
03	Compartmentation.			
	• Fire check door	Required	Provided in kitchen	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Mechanical (Exhaust)	MR
05.	Fire Extinguishers.			
	• Total numbers	04 nos.	06 nos.	MR
	• types	ABC/CO_2	ABC/CO_2	MR
	• ISI marking	Required	Provided	MR

06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main Pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby pump out put	N/A	N/A	N/A
	➢ Standby pump Head	N/A	N/A	N/A
	➢ Auto Starting /Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➢ Discharge of pump	450 lpm	900 lpm	MR
	➢ Head of the Pump	40 m	40 m	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	20,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/24.

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under rule, **It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.**

29/07/2026.

Signature of the Inspecting Officer
Name :-Deepak Kumar
Designation :-ADO (Shahdara)

DO (ED)
04/08/26

CFO (East Zone)
4/8/26

Principal Director

CFO AO issue
CID

CFO (East)
14/8/26

ADO/SHAH
Sir, F.T. letter is put up for your kind signature
pl.
18/08/2026

CFO (East Zone)
18/8/26

MS
Deemed approved.