C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2026/Collage/136

Dated: 16 /02 /2026

To

The Executive Engineer (Engineering Cell)
Delhi Technological University
Shahbad Daulatpur, Bawana Road, Delhi-110042

Sub: Regarding issuance of fire safety certificate in r/o Academic Area of Delhi Technological University located at Shahbad Daulatpur, Bawana Road, Delhi-110042

Sir,

Please refer to your letter no. F.No.DTU/Engg.Cell/002854/Electrical/2023/3558-63 Dated 19/12/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 21/01/2025 to check the existing fire safety measures. During inspection it has been observed that the academic premise is comprised of 03 Blocks Interconnected, Ground & 03 Upper Floors Each Only. At the time of inspection Sh. Pardeep Yadav (J.E. Electric) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. The staircases door width of 92cm is provided against the requirements of 1.50m.
2. Hose reel hose is provided but not functional.
3. Terrace level fire pump capacity of 450 Lpm is provided but not functional.
4. Terrace level fire water tank inspection could not be carried out because the inspection ladder is not provided at terrace level.
5. Exit & floors signage's is not provided at strategic location in the building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of academic premises is at your own risk & responsibility.

Yours faithfully

12/02/26

S.K. Dua
Dy. Chief Fire Officer
Delhi Fire Service