GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2025/ 462 Dated 18/09/2025

To,

Authorized Signatory,
Aggarwal House, 4/14 A,
Asaf Ali Road, New Delhi-02.

Sub:- Regarding renewal of FSC in r/o Aggarwal House, 4/14 A, Asaf Ali Road, New Delhi-02.

Sir,

This has reference to letter no. nil dated 14.08.2025, on the subject cited above. In this connection it is to inform that the site was visited by the officers concerned of this department on 08/09/2025 in the presence of Mr. Agrawal and the following shortcomings were observed:-

1. Some detectors found nonfunctional.
2. Smoke management system in basement found nonfunctional and not integrated with alarm/detection system.
3. PA system found nonfunctional.
4. Hydrant is not provided at basement required to be provided at basement also.
5. Lift signage's found removed.

In view of above case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully,

17/9/2025

(Virendra Singh)
Chief Fire Officer

Copy to:-

The Commissioner of MCD, Civic Centre, New Delhi.