# GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
## HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No. F.6/DFS/MS/GH/ECN/2026/841 Dated: 09/09/2026

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM, Civic Centre,
New Delhi -110002.

**Sub: Regarding issuance of Fire Safety Certificate in respect of M/s Amaan Guest House at 984, Madarsa Hussain Bakash, Bazar Matia Mahal, Jama Masjid, Delhi -110006.**

Sir,

This is in reference to online application ID No. 2026080610335 dated 06.08.2026 on the subject cited above. In this connection, it is to inform you that the inspection of the premises was conducted by the officer concerned of this department in the presence of Mr. Rehman (Manager) on dated 12.08.2026 to verify the fire safety measures installed in the building and observed that building is comprised of Ground + 05 upper floors During inspection following shortcoming were observed:

As per clause 7.31 (vi) Fire NOC for guest-house will not be issued to those building which have more than four floors (exclude basement & stilt floors).

Further, you are advised to submit Sanctioned building plans of complete building including section/elevation, Floor plans, Terrace plan etc. on the portal.

1. Fire extinguishers are not found at some places.
2. First aid hose reel is not provided.
3. CO detectors are not provided.
4. Main control panel at reception are not provided.
5. Alternate source of power supply is not provided.
6. Fire alarm hooters are not provided.
7. Discharge of terrace pump (225 LPM) is not provided.
8. Head of terrace pump (25 mtrs.) is not provided.
9. Power supply for terrace pump is not provided.
10. Automatic operation of terrace pump is not provided.
11. Exit signage are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

8/9/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. M/s Amaan Guest House at 984, Madarsa Hussain Bakash, Bazar Matia Mahal, Jama Masjid, Delhi -110006.