C-53

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/535 Dated: - 02/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: **Regarding renewal of Fire Safety Certificate in r/o M/s Aman Imperial Guest House, 3736 to 3737, Dariba Pan, Paharganj, New Delhi - 110055.**

Sir,

Please refer your online application ID No. 2026050706483 dated 07/05/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 18/05/2026 in the presence of Sh. Suresh Kumar, Manager and following shortcomings were observed: -

1. Automatic operation of Fire pump found removed.
2. Domestic connection provided in Overhead Water storage tank is not permissible.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

1/6/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

O/C BSI

Copy to: -

1. The Manager, M/s Aman Imperial Guest House, 3736 to 3737, Dariba Pan, Paharganj, New Delhi - 110055.