d/87

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2025/ 486 Dated: 23/12/2025

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110002.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Amar Guest House** located at **Prop. No. 1647-48, Opp. Krishna Market, Pahar Ganj, New Delhi - 110055.**

Sir,

This has reference to online application I.D. No. 2025120515426 dated 05.12.2025 on the subject cited above. In this connection, it is to inform you that guest house was visited by the officer concerned of this department on 13.12.2025 in the presence Manager and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. First aid hose reel hose provided but non functional.
2. CO detectors with panel and alarm system provided but not functional.
3. Fire pump capacity of 225 LPM with 40 m head found removed.
4. Overhead water storage tank capacity of 2,500 ltrs. found removed.
5. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

22/12/25

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

o/c

Copy to:-.
The Manager,
M/s Amar Guest House at Prop. No. 1647-48, Opp. Krishna Market, Pahar Ganj, New Delhi - 55.