GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/Banqt./NDZ/2026/ 398 **Dated:** 28/04/2026

To,

Sh. Shashikant Aggarwal
M/s Ambika Palace
B-3/3, Bhajanpura Main Wazirabad Road,
Delhi-110053.

Subject:- Regarding renewal of Fire Safety Certificate in r/o M/s Ambika Palace located at B-3/3, Bhajanpura Main Wazirabad Road, Delhi-110053.

Sir,

This has a reference to MCD online application ID No. **2026040704496** dated 08/04/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 20/04/2026 in presence of Sh. Shashikant Aggarwal and observed that building comprised of basement, ground, plus three upper floors but banquet is running second and third floor. Following shortcomings were observed during time of inspection:

1. Fire check doors found removed as marked in the plan.
2. Staircase serving to basement are not segregated.
3. Smoke management system found removed in the basement.
4. Main pump capacity 2280 lpm head 40 meters, standby diesel pump capacity 2280 lpm head 40 meter & Jockey pump capacity 180 lpm head 40 meters found removed.
5. Underground water storage tank for firefighting could not checked (sealed).
6. Exit Signages/Lift Signages not provided.

Keeping in view of above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

28/4/26

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

O/C R

Copy to:-

1. The Commissioner, MCD, Dr. S.P. M. Civic Centre, Minto Road, New Delhi-110002
   MCD ID NO. **2026040704496**