C-86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6/DFS/MS/EH/2026/NZ/649 Dated.24./07./2026

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s Amitabh Restaurant** located at **Ground Floor**, E-23, Banglow Road, Kamla Nagar, Delhi 110007 Comprised of Basement, Ground and Two upper floor owned/Occupied by M/s Amitabh Restaurant was issued FSC by this department vide letter no F6/DFS/MS/EH/2017/78 dated 18/01/2017. The restaurant premise was re-inspected by the officer concerned of this department on 09/07/2026 in the presence of Mr. Amitabh Bhola (Owner) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy **Group- D "Assembly** for Ground Floor only with effect from 24/07/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/07/2026 at New Delhi by

24/7/26

(Dr. S.K Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Health Officer, (MCD), Public Health Department, Dr. Satpal Sachdeva Marg, Keshav Puram, Tri Nagar, Delhi 110034 (Ref. MCD Portal ID 2025062510551 dated 01/07/2026)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
7. This NOC is valid only Ground Floor only.

आज़ादी का अमृत महोत्सव

INSPECTION REPORT

1	Name & Address of the Building	M/s Amitabh Restaurant at E-23, GF Banglow Road, Kamla Nagar, Delhi 110007		
2	Type of Occupancy	Assembly, "Group–D" (Restaurant at Ground floor only)		
3	Building Comprised of	Basement, Ground + Two Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2017/78 dated 18/01/2017		
6	Fire Safety Directives Letter No	NBC/BBL Requirement		
7	Date of Inspection	09/07/2026		
8	Name of the Inspecting Officers	ADO (Model Town)		
9	Name & Designation of Officers from the building side	Mr. Amitabh Bhola (Owner)		
10	Year of construction	1994 as per MCD Portal		
11	Applicant letter No.	MCD Portal ID 2025062510551 dated 01/07/2026		
S. No	**Minimum standards on Fire Prevention and Fire Safety U/R 33**	**Requirements BBL/NBC**	**Provided at Site**	**Remarks MR/NMR**
1	**Access to Building.**			
	• Road width	09 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	**Number, width, type & arrangement of exits.**			
	a) Number of Staircase			
	➢ Upper floors.	01 No	02 Nos	MR
	➢ Basement floor.	02 Nos	02 Nos	MR
	b) Width of Staircase			
	➢ Upper floors	1.25 mtr	1.25 m & 1.16 m	MR (old case)
	➢ Basement floor	1.50 mtr	1.50 m & 2 m	MR (old case)
	c) Protection of exits			
	➢ Fire check door	-N/A-	-N/A-	-N/A-
	➢ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	2.0 mtr	2.0 mtr	MR (old Case)
3	**Compartmentation.**			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4.	**Smoke Management system.**			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Natural Ventilation	MR
5.	**Fire Extinguishers.**			
	• Total numbers	Required	06 Nos	MR
	• Types	ABC / CO2	ABC-03 & CO_2-03	MR
	• ISI Marking	ISI marked	Provided	MR
6.	**First Aid Hose Reels.**			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

आज़ादी का अमृत महोत्सव

7	**Automatic fire detection & alarming system.**			
	• Type of detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	-N/A-	-N/A-	-N/A-
10.	**Automatic Sprinkler System**			
	• Basement.	Required	Provided	MR
	• Upper floors	-N/A-	Provided	-N/A-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	**Internal Hydrants.**			
	• Size of Riser / Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	One	Provided	MR
	• Hose box.	One	Provided	MR
12.	**Yard Hydrants.**			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	**Pumping arrangements.**			
	• **Ground Level**			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➢ Head of main pump.	-N/A-	-N/A-	-N/A-
	➢ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➢ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➢ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➢ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➢ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➢ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➢ Pump house access.	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
	• **Terrace Level**			
	➢ Discharge of pump.	450LPM	Provided	MR
	➢ Head of pump.	180m	Provided	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14.	**Captive water storage for firefighting.**			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➢ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➢ Fire Service Inlet.	-N/A-	Provided	-N/A-
	➢ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	20,000 ltrs	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
17	**Standby Power Supply**	Required	Provided	MR

18.	**Refuge Area**			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	**Fire Control Room.**			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	**Special Fire Protection System for the Protection of special Risk, if any.**	-N/A-	-N/A-	-N/A-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2017/78 dated 18/01/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

10/07/2026

Signature of the Inspecting Officer
Name: Sh. Sumit Kumar
Design: ADO (MT)

DO (CN) 11/07

CFO/N2 11/7/26

Principal Director

Is it a guest house or restaurant? (A compare the previously issued FSC & the DFA.)

14/7/26

CFO(N2). There are two seperate FSCs issued for two occupancies C/42 – Restaurant and C/63 – Guest House. Re-submitted pl. 24/7/26

Principal Director