e/125

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2026/ 492 Dated: - 19 / 05 /2026

To,

The Director (Bldg.), DDA
C-1/112, Vikas Sadan, INA,
New Delhi- 110023.

Sub: - Regarding issuance of "FSC" from fire safety point of view in r/o Vankateshwar International School located at Sector- 10, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter dated 20.04.2026 received through online email Id directorbuldingdda@gmail.com, on the subject cited above. In this connection it is to inform you that the above said school building inspected by the officer concerned of this department, in the presence of Principal/HOS on dated 05.05.2026, to check the status of the shortcomings already pointed out by this department vide letter No F.6/DFS/MS/School/2026/SZ/253 dated 27.03.2026, which are still not complied.

In view of the above, issued/ renewal of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter, and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

19/5/26

(A. K. Malik)
Chief Fire Officer
South Zone

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.
2. The Principal, Vankateshwar International School, Sector- 10, Dwarka, New Delhi-110075.

C-128

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2026/SZ/ 253 **Dated:** 27/03/2026

To,

The Principal,
Vankateshwar International School,
Sector- 10, Dwarka, New Delhi-110075.

Sub: - Regarding issuance of "FSC" from fire safety point of view in r/o Vankateshwar International School located at Sector- 10, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter received through DDA application File No. W10/0169/2023_OCC, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 13.03.2026 in the presence of Sh. Ansul Goyal, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school running at basement, ground plus four upper floors. The FSC was also issued vide letter No. F.6/DFS/MS/School/2025/SZ/953 dated 07.08.2025 (for B, G+3 upper floors only) but now school management running classes at 4th floor and following shortcomings observed: -

1. 6.0 m wide internal road all around the building found not provided at three side of building.
2. Fire Check doors found not provided.
3. Electrical shaft found not sealed.
4. First aid hose reels/hydrant found provided but not functional.
5. MOEFA found provided but not functional.
6. Automatic Sprinkler system not provided in left out area (Basement).
7. Ground level fire pumps of 2280 LPM electric pump, 2280 LPM standby diesel pump and one jockey pump of 180 LPM found not provided and terrace level fire pumps provided as per requirement but found not functional in auto mode.
8. Underground water storage tank of 1,50,000 ltrs found not provided and overhead water storage tank of 10,000 ltrs. found provided against requirement of 25,000 ltrs.
9. Exit signage's are found not provided at some places.
10. Pressurization of lift shaft, lift lobby and staircase found not provided.
11. Fire Control Room found not provided.

In view of above, the fire safety certificate issued vide letter dated 07.08.2025 is rejected with immediate effect. Therefore, you are requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

25/3/26

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to:-

1. The Dy. Director, Delhi Development Authority, Vikas Sadan, INA, New Delhi- 23.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.