GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का अमृत महोत्सव

C14

No. F6/DFS/MS/EH/SZ/2026/65 Dated: 21/01/2026

To,

The Commissioner,
Municipal Corporation of Delhi
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Aridii The Coastal Kitchen (Curry Leaf Restaurant Private Limited located at Plot No. 2, G Block Market, Hauz Khas, New Delhi – 110016.

Sir,

This has a reference to your MCD Portal application No. 2025122916191 dated 02/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/01/2026 in the presence of Mr. Vikramjit Singh (Owner) and observed that building comprised of Basement, Ground plus three upper floors. **(But Restaurant running on ground floor only.**

Following shortcomings were observed during time of inspection:

1. Smoke Management System not provided in upper floors.
2. Fire extinguishers not provided.
3. First-Aid-Hose Reel provided but not functional.
4. MOEFA provided but not functional.
5. Internal Hydrants provided but not functional.
6. Terrace level fire pump capacity of 450 LPM provided but not functional.
7. Terrace fire water tank capacity of 20,000 liters provided but found empty.
8. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

21/1/26

A. K. Malik
Dy. Chief Fire Officer
Delhi Fire Service
O/C (W)