GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2025/ 531 Dated: 11 / 11 /2025

To,

The Authority Signatory,
Arun Hosiery Mill
Shed No. 151, Okhla Industrial Estate,
Phase – III, New Delhi – 110020.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Arun Hosiery Mill located at Shed No. 151, Okhla Industrial Estate, Phase – III, New Delhi – 110020.

Sir,

This has a reference to your outdoor dairy No. 6731 dated 06/10/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 27/10/2025 in the presence of Mr. S. K Sharma and observed that building comprised of Basement, Stilt, Ground plus two upper floors and following shortcomings were observed during time of inspection:

1. Fire Check Door found removed.
2. Smoke Management System found removed.
3. Automatic Sprinkler System provided but not functional.
4. Fire pump of capacity 900 LPM provided but not functional.
5. Overhead water storage tank of capacity 20,000 liters is provided against requirement of 25,000 liters.
6. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A.K.Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi - 110024.