GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No.F6/DFS/MS/Hospital/NDZ/2026/208 Dated: 30/05/2026

To,

The Assistant Engineer
HMED(C), PWD, HC-5
AAAGH, Rajpur Road,
New Delhi – 110005

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Aruna Asaf Ali Hospital, Rajpur Road, Delhi – 110054.

Sir,

Please refer your letter No. संख्या 1(3)स.अभी.(वै)/लो.नि.वि/एच् सी -5/2026-27/90 dated 22.04.2026 on the subject citied above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 18.05.2026 in the presence of Sh. Kaushik Chaudhary (JE), and following shortcomings were observed: -

1. Automatic Sprinkler System in basement Provided but found non-functional.
2. Overhead water storage tank of capacity 10,000 liter found removed.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be consider at this stage and stands **rejected.** Further, the occupancy of the building/premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Further, you are requested to apply through online DFS portal for renewal of FSC.

Yours Faithfully,

29/05/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service