GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 380 Dated: 24/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Arya Tourist Lodge Guest House, 8526, Arakashan Road, Ram Nagar, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026033003844 dated 30/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 09/04/2026 in the presence of Sh. Varun Pahuja, Owner and following shortcomings were observed: -

1. Fire Check door was not provided at Ground Floor.
2. Smoke Management system provided but found non-functional.
3. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
4. Automatic operation of Fire pump found removed.
5. Domestic connection provided in Overhead Water storage tank is not permissible.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

24/4/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s Arya Tourist Lodge Guest House, 8526, Arakashan Road, Ram Nagar, Paharganj, New Delhi - 110055.