c/31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2025/ 814 Dated: 17 /11 /2025

To

The Principal,
Atma Ram S. D. Senior Secondary School,
Ajmeri Gate, Delhi - 110006.

Sub: - Regarding issuance of "**Fire Safety Certificate**" from fire safety point of view in **r/o Atma Ram S. D. Senior Secondary School, Ajmeri Gate, Delhi - 110006.**

Sir,

This has reference to letter outdoor diary No. 6313 dated 23.09.2025 on the subject cited above. In this connection, this is to inform you that the school building was visited by officer concerned from this department on 03.11.2025 in the presence of Mr. Manish Sharma, PGT (Commerce) and observed that the school building is comprised of ground plus one upper floor (two blocks) and have complied the shortcomings issued vide letter no. F6/DFS/MS/NDZ/School/2025/585 dated 11.07.2025 except following which still exists:-

1. The width of single staircase in each block is less than 1.50 meter therefore an additional fire escape staircase not less than 0.75 meter wide shall be provided for each block.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

14/11/25

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-.
The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.