C-311

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001

आज़ादी का अमृत महोत्सव

No:F6/DFS/MS /NDZ/2026/120 Dated: 22/06/2026

FIRE SAFETY CERTIFICATE

Certified that the **Auditorium Hall at 4,5,6th floor of "C" Block** building comprised of **Basement + Ground + 05 upper floor** located at **Dr. SPM Civic Centre Minto Road, J.L.N Marg, New Delhi** was earlier granted FSC by this department vide letter No. **F6/DFS/MS/NDZ/2023/141 dated 14.03.2023**. Now, the premises was re-inspected by the officers concerned of this department on 21.05.2026 in the presence of Mr. Rakesh Kumar Jha (Manager) and found that the auditorium has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises at 4, 5 & 6th floor is fit for occupancy class **"Assembly Building (Auditorium)" with effect from 22/06/2026 for a period of three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 22/06/2026 at New Delhi by

19/6/26

(Dr. S. K. Tomer)
Chief Fire Officer
Delhi Fire Service

O/C 19/6

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 02.
2. The President, Auditorium Hall at 4,5,6th floor of "C" Block in Dr. SPM Civic Centre Minto Road, J.L.N Marg, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	**Name and address of the building:**	**Auditorium Hall at 4, 5, 6th floor of "C" Block in Dr. SPM Civic Centre Minto Road, J.L.N Marg, New Delhi.**
2.	**Type of occupancy with details of floors:**	**Assembly Building at 4,5,6th floor of Basement + Ground + 05 upper floor**
3.	**Type of case:**	Renewal
4.	**Details of previous NOC:**	F6/DFS/MS/NDZ/2023/141 dated 14.03.2023
5.	**Fire safety directives no.:**	NA
6.	**Date of inspection:**	21.05.2026
7.	**Name of the inspecting officer:**	Sh. Manish Kumar (DO/CD) Sh. Sumit Kumar (ADO/HQ)
8.	**Name and designation of the officer from the building side:**	Mr. Rakesh Kumar Jha (Manager)
9.	**Year of construction:**	2010
10	**Reference letter no.:**	online application ID 52026010900194

S,No		Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (as per NOC dated 12.09.2018)	Provided at site	Remarks MR/NMR
1	**Access to Building**				
	A	Road width	12 mtr	12 mtr.	MR
	B	Gate width	05 mtr.	06 mtr.	MR
	C	Width of internal roads	06 mtr.	06 mtr.	MR
2	**Number, Width, Type & Arrangement of Exits**				
	A	No. Of Staircase:			
		a) Upper Floor	06 Nos.	08 Nos	MR
		b) Basements	NA	NA	NA
	B	Width of the Staircase:			
		a) Upper floors	02 nos. 02 mtr. & 4 nos, 1.25mtr. & 2 nos. 1 mtr.	2 nos 2 mtr., 1 nos. 1.5 mtr. & 3 nos. 1.25 mtr. & 2 nos. 1 mtr	MR
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire Check Door	Required	Provided	MR
		b) Pressurization	Required	Provided	MR
	D	No. Of continuous staircase to terrace:	06 no.	08 nos.	MR
	E	Width of the corridor	02 mtr.	02 mtr.	MR
	F	Door size	02 mtr.	02 mtr.	MR
3	**Compartmentation:**				
	A	Fire Check doors	Required	Provided	MR
	B	Sealing of Electrical Shafts	Required	Provided	MR
	C	Fire rating of shaft Doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	Required	Provided	MR
4	**Smoke management System:**				
	A	Basements	30ACPH	Provided	MR
	B	Upper floors	12 ACPH	Natural	MR
5	**Fire extinguishers**				
	A	Total numbers	120 nos.	120 nos.	MR
	B	Types	CO_2, ABC	Provided	MR
	C	ISI marking	Required	Provided	MR

6	**First Aid Hose reel**				
	A	Total no. at each floor	04 no.	04 no.	MR
	B	Length of Hose Reel	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	**Automatic Fire Detection and Alarm System (ADAS):**				
	A	Type of Detectors	Required	Provided	MR
	B	Location of main Panel	Gr. floor	Provided	MR
	C	Location of Repeater Panel	Required	Provided	MR
	D	Alternate power Source	Required	Provided	MR
	E	Hooter's location			
8	**MOEFA**		Required	Provided	MR
9	**Public Address System**		Required	Provided	MR
10	**Automatic Sprinkler System**				
	A	Basement	Required	Provided	MR
	B	Upper Floor	Required	Provided	MR
	C	Sprinklers above false ceiling	Required	Provided	MR
11	**Internal hydrants**				
	A	Size of the riser/down comer	150 mm	150 mm	MR
	B	No. Of hydrants per floor	04 no.	04 no.	MR
	C	Hose box per floor	04 no.	04 no.	MR
12	**Yard Hydrants**				
	A	Total no. of hydrants	09	09	MR
	B	Hose box	09	09	MR
13	**Pumping arrangements**				
	A	Ground Level			
		a) Discharge of main pump	2850 LPM	2850 LPM	MR
		b) Head of main pump	150 mtr.	150mtr.	MR
		c) Number of main pump	02	02	MR
		d) jockey pump output	180 LPM	180 LPM	MR
		e) Head of jockey pump	70, 110 & 50 mtr.	70, 110 & 50 mtr.	MR
		f) Standby pump output	2850 LPM	2850 LPM	MR
		g) Head of Standby pump	150 mtr.	150 mtr.	MR
		h) Auto starting/ manual stopping	Required	Provided	MR
	B	Terrace Level			
		a) Discharge of terrace pump	NA	NA	NA
		b) Head of terrace pump	NA	NA	NA
		c) Alternate power supply	NA	NA	NA
		d) Auto starting of pump	NA	NA	NA
14	**Captive Water Storage for Fire Fighting**				
	A	Underground tank capacity	2,00,000 ltrs.	3,00,000 ltrs.	MR
	B	Draw off connection	Required	Provided	MR
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	30,000 ltrs.	30,000 ltrs.	MR
15	**Exit Signage**		Required	Provided	MR
16	**Provision of lift**				
	A	Pressurization of lift shaft	Required	Provided	MR
	B	Pressurization of lift lobby	Required	Provided	MR
	C	Communication in lift car	Required	Provided	MR
	D	Fireman switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	**Standby Power Supply**		Required	Provided	MR

18	**Refuge Area**				
	A	Location	NA	NA	NA
	B	Total area	NA	NA	NA
19	**Fire Control Room:**				
	A	Fire Detection System panel	Required	Provided	MR
	B	Flow switch panel	Required	Provided	MR
	C	P A system panel	Required	Provided	MR
	D	Battery backup	Required	Provided	MR
	E	Building floor plan	NA	NA	NA
20	**Special Fire Protection for special risk if any**				NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/NDZ/2023/141 dated 14.03.2023 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer
Name : Sumit Kumar
Designation : ADO (HQ)

10/06/26

Signature of the Inspecting Officer
Name : Manish Kumar
Designation : DO(CD)

CFO (NDZ)
17/6/26

Principal Director

CFO to Issue.
18/06/26

CFO (EEN)
18/6/26

ADO (HQ)
F.T. letter is put up for signature, Please.
19/06/2026

C.F.O. (NZ)
19/6/26

ms