GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2026/NZ/ 799 Dated: 25/08/2026

To,

The Principal,
Educational Public School,
B-2, 80 yards Colony, Jeevan Park,
Siraspur, Delhi- 110042.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Educational Public School located at B-2, 80 yards Colony, Jeevan Park, Siraspur, Delhi- 110042.

Sir,

This has reference to your Email ID dated 02/07/2026 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.08.2026 in presence of Sh. Kamal Arora to see the compliance of requisite fire safety measures. During the course of inspection, it is observed that school building is comprised of Ground plus 02 Upper Floors. Your request for issuance of FSC is rejected due to the following shortcomings:

1. Road width found 4.8 m against the required width of 6 m.
2. Width of staircase found 1.10 m and 0.90 m against the required width of 1.5 m each.
3. Passage to the alternate staircase is not permitted through the classroom.
4. Door width found 1 m against the required width of 1.2 m.
5. Overhead tank of 4400 ltr water storage capacity found provided against the requirement of 10,000 ltr.
6. Exit signages found not provided.
7. Building plan in a scale of 1:100 duly signed by registered architect and owner is not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

24/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.