GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/Industrial/SZ/2025/ 01 Dated 02/01/2026

To,

The Owner/Occupier/Manager,
Plot No. B - II/27, Mohan Co-Operative Industrial Area/Estate,
Mathura Road, Badarpur, New Delhi – 110044.

Subject: - Regarding Renewal of Fire Safety Certificate in r/o Plot No. B - II/27, Mohan Co-Operative Industrial Area/Estate, Mathura Road, Badarpur, New Delhi – 110044.

Sir,

With reference to the letter berating Online Application No. 25025120100203, on the subject cited above. It is informed, that the said building/premises was inspected by the officer concerned of this department on 15/12/2025 in the presence of Mrs. Shaleen Virmani Karnik and following shortcomings were observed during time of inspection:

1. Fire check door found removed some places.
2. Smoke Management System found removed in basement and upper ground.
3. First-Aid Hose reel provided but not functional.
4. Automatic sprinkler system provided in basement found not functional.
5. Internal Hydrants provided but not functional.
6. Fire pump of capacity 900 LPM provided but not functional.
7. Overhead water storage tank of capacity 20,000 liters provided but found empty.
8. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

1/1/26

(A.K Malik)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE
O/C (W)

Copy to: -

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi – 110024.