GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2026/WZ/ 560 Dated: 9/06/2026

To,

The Principal,
Bal Bharti Modern School,
Main Rohtak Road,
Tikri Kalan, Delhi-110041.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Bal Bharti Modern School located at Main Rohtak Road, Tikri Kalan, Delhi- 110041.

Sir,

This has reference to your email id dated 24.05.2026 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 02.06.2026 in presence of Smt. Neelam to see the compliance of requisite fire safety measures.

Your request for issuance of FSC is rejected due to the following shortcoming: -

1. Width of staircase found 1.5 m and 0.85 m against the required width of 1.5 m each.

You are advised to rectify the above-mentioned shortcoming under intimation to this department.

Yours Faithfully

05/06/26

S.K. Dua
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.