C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/ 164 Dated:- 09/10/2026

FIRE SAFETY CERTIFICATE

Certified that the Bal Bharti Modern School located at Main Rohtak Road, Tikri Kalan, Delhi- 110041, comprised of Ground plus Two upper floors, owned/occupied by Bal Bharti Modern School have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Service Rules- 2010 and verified by the officer concerned of Fire Service on 15/09/2026 in the presence of Mrs. Neelam Sharma (Principal) of the school and that the school building/premise is fit for occupancy class "Educational Building" Group B with effect from 09/10/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 09/10/2026 at New Delhi by

8/10/26

A.K. Malik
Chief Fire Officer

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Bal Bharti Modern School, Main Rohtak Road, Tikri Kalan, Delhi- 110041.

8/C
08/10/26

Conditions for validity of fire safety certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire-fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub-Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Bal Bharti Modern School located at Main Rohtak Road, Tikri Kalan, Delhi- 110041		
2.	Type of Occupancy	Educational		
3.	Building comprised of	Ground plus Two upper floors		
4.	Type of Case	New		
5.	Details of previous NOC	Nil		
6.	Fire Safety directives letter No	NBC Part IV		
7.	Date of inspection	15/09/2026		
8.	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JKP)		
9.	Name and designation of officers from the building side	Mrs. Neelam Sharma, Principal		
10.	Year of Construction	2024		
11.	Applicant's letter no.	Nil dated 10/08/2026		
S. No.	**Minimum Standards on fire prevention and fire safety U/R 33**	**NBC Part IV Requirements**	**Provided at site**	**Remarks MR/NMR**
1	**Access to building**			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	On Road	MR
	• Width of internal road	NA	NA	NA
2	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	02 nos.	02 nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m each	1.50 m x 2 & 0.85 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.20 m	Provided	MR
3	**Compartmentation.**			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	**Smoke Management System.**			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	**Fire Extinguishers**			
	• Total numbers	04 nos.	05 nos.	MR
	• Types	ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	**First-Aid Hose Reels.**			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7	**Automatic fire detection and alarming system.**				
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8	**MOEFA**	NA	NA		NA
9	**Public Address System.**	NA	NA		NA
10	**Automatic Sprinkler System.**				
	• Basement	NA	NA		NA
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11	**Internal Hydrants**				
	• Size of riser/down-comer	NA	NA		NA
	• Number of hydrants per floor	NA	NA		NA
	• Hose Box	NA	NA		NA
12	**Yard Hydrants.**				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13	**Pumping Arrangements.**				
	• Ground Level				
	➢ Discharge of main Pump	NA	NA		NA
	➢ Head of Main pump	NA	NA		NA
	➢ Number of main pumps	NA	NA		NA
	➢ Jockey Pump out put	NA	NA		NA
	➢ Jockey pump head	NA	NA		NA
	➢ Standby Pump out put	NA	NA		NA
	➢ Standby Pump Head	NA	NA		NA
	➢ Auto Starting/ Manual stopping	NA	NA		NA
	➢ Pump House Access	NA	NA		NA
	• Terrace level				
	➢ Discharge of pump	450 LPM	Provided		MR
	➢ Head of the pump	40 m	Provided		MR
	➢ Power Supply	Required	Provided		MR
	➢ Auto Starting of pump	Required	Provided		MR
14	**Captive Water Storage for fire fighting.**				
	• Underground tank capacity	NA	NA		NA
	➢ Draw-off connection	NA	NA		NA
	➢ Fire service inlet	NA	NA		NA
	➢ Access to tank	NA	NA		NA
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs		MR
15	**Exit Signage.**	Required	Provided		MR

16	**Provision of Lifts.**			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	**Standby power supply**	NA	NA	NA
18	**Refuge Area.**			
	➢ Total Area	NA	NA	NA
	➢ Location	NA	NA	NA
19	**Fire Control Room**			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the school building/premises were checked and found functional at the time of inspection. The shortcomings issued vide letter no. F.6/DFS/MS/School/2026/WZ/560 dated 09/06/2026 found rectified.

Keeping in view of the substantial compliance of the minimum standards of fire prevention & fire safety measures as required under rule 35 of Delhi Fire Service Rules 2010, it **is recommended** to grant Fire Safety Certificate.

Accordingly, DFA is prepared & put up for approval please.

17/09/26

Aman Kumar Lathar
ADO (JKP)

ADO(SW)

18/9/26

DFO (WZ)

CFO (WZ)

23/09/2026

Debabrata Mukherjee

24/9/26

A.K. MALIK

Pr. DG. When did we receive application?

CFO (WZ)

20/9