C-39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/777 Dated: 17/10/2025

To

The Principal,
Bal Bhavan Public School,
A-Block, Swasthya Vihar,
Delhi-110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o Bal Bhavan Public School located at A- Block Swasthya Vihar, Delhi-110092.

Sir,

This has a reference to your Outdoor Dairy No. 6014 dated 16/09/2025 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 27/09/2025 in the presence of Ms. Rachna Gupta (Principal) and observed that school building comprised of Basement, Ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. 02 staircase of width 1.50 meter & 1.20 meter provided against the requirement of 02 staircase of width 1.50 meter each on upper floors.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

14/10/25

Dr. S.K. Tomar
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

o/c 10/10/25

1. Director of Education, GNCT of Delhi, Old Secretariat, Civil Lines, Delhi-110054.