C-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2026/School/WZ/ 469 Dated: 14 / 05/2026

To

The Principal
Bal Vidya Mandir Convent School
Pooth Kalan, Sector-20, Rohini,
Delhi-110086

Sub: - Regarding issuance of fire safety certificate in r/o Bal Vidya Mandir Convent School located at Pooth Kalan, Sector-20, Rohini, Delhi-110086.

Sir,

Please refer to your letter received through e-mail dated 06/04/2026 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 16/04/2026 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floor only. At the time of inspection Smt. Amrita Mishra (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. The main gate width 03m are provided against the requirement of 4.50m.
2. 02 nos. of staircases having width 1.50m and 1.40m are provided against the requirements of 1.50m each and both staircases continues from ground to terrace level are not provided.
3. The classrooms door size 01m are provided against the requirement of 1.20m.
4. Hose reel hose is not provided.
5. Terrace level fire pump capacity of 450lpm is not provided.
6. Terrace level fire water tank capacity of 10,000 Ltr is not provided.
7. Exit & floors signage's is not provided at strategic location in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

13/05/26

(S.K. Dua)
Chief Fire Service
Delhi Fire Service

C/C 6

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.