GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/SZ/2026/ 43 Dated 17/02/2026

To,

Authorized Signatory,
Banquet Hall (Panashe) the Nikunj,
Kh. No. 33/13, 33/8/1, Ground Floor,
Village Samalkha, New Delhi.

Sub:- Regarding issuance of FSC in r/o Banquet Hall (Panashe) the Nikunj located at Kh. No. 33/13, 33/8/1, at Ground Floor, Village Samalkha, New Delhi.

Sir,

This has reference to online id no. 2026011700611 dated 17.01.2026, on the subject cited above. In this connection it is to inform that the site was visited by the officers concerned of this department on 11/02/2026 in the presence of Mr. Sanjay Kaushik, Manager and the following shortcomings were observed:-

1. First aid hose reel & Hydrant is not covering entire area of banquet , required to be extended to left out area .
2. Fire check door is not provided at the staircase serving to basement for Compartmentation.

In view of above case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

(M.K.Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service
O/C (W)

Copy to:-

The Commissioner of MCD, Civic Centre, New Delhi.