GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/EH/2026/EZ/ 840 Dated: 09 / 09 /2026

To

The Commissioner,
Municipal Corporation of Delhi,
9th Floor, Dr. SPM Civic Centre,
JLN Marg, New Delhi–110002

Sub: **Regarding issuance of Fire Safety Certificate in r/o M/s Bansi Wala Sweets at Property No. C–54-56, Ground floor & First floor, East Krishna Nagar, Delhi–110051**

Sir,

Please refer to MCD online application No. **2026080510302** dated 05/08/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officers concerned of this department on 19/08/2026 in the presence of Mr. Rajesh to verify the availability and operability of the fire and life safety provisions required under the rules. During course of inspection, the shortcomings observed are as below.

1. The width of staircases provided are 1.70m, 1.20m, 0.80m & 1.0m against required clear width of 1.50 meter of two of the staircases.
2. The required FCDs are not found provided.
3. The width of one of the exits at first floor found 1.20m against required width of 1.50m
4. Sprinkler system in some portion at first floor not found provided as indicated during inspection.
5. The exit signage is not provided at conspicuous locations.

In view of the above, application for issuance of fire safety certificate cannot be considered at this stage and hence, rejected. The occupancy of the premise in the absence of requisite fire and life safety provisions shall be at the risk and liability of the owner/occupier.

Yours faithfully,

8/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Shiv Dayal, M/s Bansi Wala Sweets, C–54-56, East Krishna Nagar, Delhi–110051