Azadi Ka Amrit Mahotsav C-56

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/2025/WEST ZONE/ EH/497 Dated 29/12/2025

To,

The Commissioner (MCD),
SPM Civic Centre,
JL Nehru Marg, Delhi-110002

Sub:- Special Drive for surprise inspection in r/o eating houses / restaurants in Delhi from Fire prevention & Fire Safety point of view.

Sir,

As per the office order No. F6/DFS/HQ/2025/2127 dated 10/12/2025, surprise inspection of eating house namely Barbeque Nation (A unit of M/s Barbeque Nation Hospitality Ltd.) at 2nd & 3rd floor, Property No.-B2, Gujrawala Town Part-1, Delhi-110009 was conducted by officer of this department on dated 16/12/2025 in the presence of Sh. Gautam (Captain) to ascertain the availability & operability of the Fire prevention & Fire Safety measure provided in the building and following observation were made during the time of inspection.

1. Fire Pump of capacity 2280LPM (Diesel) found removed.
2. Overhead tank of capacity 80,000 ltr provided against requirement of 1,00,000ltr +10,000 ltr i.e. 1,10,000ltr.
3. Fire Check Door on front side found removed.
4. 2nd door in kitchen not provided.
5. Internal Hydrant, Hose Reel & Sprinkler system found nonfunctional.
6. Exit signages found removed.

The above-mentioned shortcomings should be complied latest by 30 days (i.e.16/01/2026).

Keeping in view of above, Fire Safety Certificate issued by this department vide letter F6/DFS/MS/2023/EH/300 Dated 04/10/2023 to the **restaurant will remain suspended** until the compliance of the above mentioned shortcomings. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully

24/12/25

(S.K. Dua)
Dy. Chief Fire Officer (WZ)

Copy to:-

1. Sh. Gautam (Captain), Barbeque Nation (A unit of M/s Barbeque Nation Hospitality Ltd.) at 3rd floor, Property No.-B2, Gujrawala Town Part-1, Delhi-110009. O/C A