GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/ 270 Dated 13 /02 /2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Base Kitchen Khan Chacha (A Unit of Gupta and Gupta Private Limited located at Property No. 46, Ground floor, Okhla Industrial Estate, Phase – III, New Delhi – 110020.

Sir,

This has a reference to MHA application No. 2026012300825 dated 24/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 04/02/2026 in the presence of Mr. Nafees (Manager and observed that building comprised of Ground floor only, following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel provided but not functional.
2. MOEFA found removed.
3. Internal Hydrants provided but not functional.
4. Hose box found removed.
5. Terrace fire pump found removed.
6. Overhead tank of 20,000 liters capacity but found removed.
7. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

A.K. Malik
Dy. Chief Fire Officer
Delhi Fire Service