आज़ादी का अमृत महोत्सव C-16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/2026/816 Dated: 27/08/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in respect of M/s. Haldiram Marketing Pvt Ltd, located at C-197 Jawahar Park, Village Khanpur, Tehsil Hauz Khas, Main Khanpur, Devli Road, New Delhi-110062.

Sir,

Please refer to your online application ID No. 2026071309748 dated-13/07/2026, on the subject cited above. In this connection, it is to inform you that the premise was inspected by officer concerned of this department on 27/07/2026 in the presence of Sh. Jitender (Manager) to see the functioning of fire safety arrangements/equipments provided in the building. During inspection the following shortcomings were observed.

1. Staircases & Door sizes both of width 1.50m are provided against requirement of 2m and 1.5m.
2. Main Fire Pump capacity of 900LPM is provided but not on auto-mode.
3. Exit signage's not provided.

In view of above, the application for issuance of Fire safety Certificate is cannot consider at this stage.

Yours faithfully,

27/08/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier, M/s. Haldiram Marketing Pvt Ltd, located at C-197 Jawahar Park, Village Khanpur, Tehsil Hauz Khas, Main Khanpur, Devli Road, New Delhi-110062. (Online application No. 2026071309748 dated-13/07/2026).