GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/224 Dated 17/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o Café 27 Bar & Kitchen located at HS - 26, Second & third floor, Kailash Colony Market, GK- I, New Delhi – 110048.

Sir,

This has a reference to MHA application No. 2026021701714 dated 17/02/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 07/02/2026 in the presence of Mr. Shabad Singh Mehta (Owner) and observed that building comprised of Ground plus three upper floors Restaurant running on 2nd & 3rd floor only.

Following shortcomings were observed during time of inspection:

1. Smoke management System provided but not functional.
2. First Aid Hose Reel provided but not functional.
3. MOEFA provided but not functional.
4. Internal hydrant provided but not functional.
5. Fire pumps provided but not functional.
6. Fire tank provided but found empty.
7. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

13/3/26

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
o/c (W)