C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/2025/EH/WZ/ 501 Dated 31/12/2025

To

The Commissioner,
Municipal Corporation of Delhi
S.P. M Civic Centre,
J.L. Nehru Marg, New Delhi-110002.

Sub: - Surprise inspection of Eating House/Restaurant Namely M/s Caffeinated Enterprises, Shop No. 604, sixth floor, Unity One MLCP, Complex, Delhi-110085.

Sir,

A surprise inspection of above said restaurant was conducted by this department on dated 13/12/2025 to view the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/EH/WZ/2023/649 dated 29/11/2023.

S No.	Shortcomings	Status
1.	The width of doors size is 01m & 1.10m against the required width of 1.50m each	Not Complied
2.	Fire extinguisher are not provided	Complied
3.	Smoke ventilation system is not provided.	Not Complied
4.	The required exits signage's are not provided.	Not Complied

Keeping in view of above, applicant is directed to comply the above mentioned shortcomings under 30 days (12/01/2026) time given occupancy of the building till such time running of restaurant is at own risk & responsibility of the owner.

Yours faithfully

29/12/25

S.K. Dua
Dy. Chief Fire Officer
Delhi Fire Service