GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/SZ/2025/ EH / 423 Dated: 06 / 11 /2025

To,

Mr. Prince Chawla (Owner),
Chawla Food,
GI - 98, Mayapuri Industrial Area Phase-2,
New Delhi - 110064.

Subject: - Regarding issuance of Fire Safety Certificate in r/o Chawla Food at GI - 98, Mayapuri Industrial Area Phase - 2, New Delhi - 110064.

Sir,

This has a reference to your MCD portal application No. 2025092713791 dated 07/10/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 23/10/2025 in the presence of Mr. Prince Chawla (Owner) and observed that building comprised of Ground plus two upper floors + terrace floor (SPS).

Following shortcomings were observed during time of inspection:

1. One staircase of 1.20 meter provided against the requirement of 02 nos. of 2.00 meters each.
2. Fire check door not provided.
3. Door size of 1.25 meter provided against the requirement of 2.00 meters.
4. Smoke management system not provided.
5. First-aid-Hose Reels not provided.
6. Automatic fire detection system not provided.
7. MOEFA not provided.
8. PA system not provided.
9. Automatic sprinkler system not provided.
10. Internal hydrant & yard hydrant not provided.
11. Fire pump of capacity 2280 LPM (electrical) one diesel pump of capacity 2280 LPM and one Jockey pump of 180 LPM are not provided.
12. Terrace level fire pump of capacity 900 LPM not provided.
13. Underground water tank of capacity 1,00,000 liters & Overhead water tank of capacity 20,000 liters not provided.
14. Exit & floors Signage's not provided in strategic location in the building .
15. Lifts signage to be provided at all lifts.
16. Standby power supply not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

6/11/25

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

O/C (Q)

1. The Commissioner, MCD Civic Center, New Delhi, w.r.t.- MCD portal ID - 2025092713791 dated 07/10/2025.