GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/Redl/2026/SZ/ 97 Dated: 06 / 04 /2026

To

The Dy. Inspector General,
SHQ (L&C), I.T.B. Police,
Ministry of Home Affair (G.O.I),
Najafgarh Road, Chhawla Camp.
New Delhi–110071

Sub: Issuance of Fire Safety Certificate for residential and non-residential buildings at Chhawla Camp premises of ITBP

Sir,

This has a reference to your office letter No. II-35015/SHQ(L&C)/Engr.Br./2025-01 dated 11/03/2026 received vide outdoor diary No. 11726 dated 12/03/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 17/03/2026 in the presence of Sh. Ashok Kr. Bishnoi (Second in Command Engr) to verify the compliance of shortcomings earlier issued vide letter No. F6/DFS/MS/2022/SZ/2990 dated 29/11/2022 in respect of Barrack Building (G+5). During the inspection it was observed that the shortcomings have not been rectified as yet. In addition to shortcomings earlier issued, other shortcoming has also been observed. Thus, the cumulative shortcomings are as below.

1. Smoke management system provided but not functional.
2. First aid hose reel provided but not functional.
3. Manual Operated Electric Fire Alarm provided but not functional.
4. Public addressing system provided but not functional.
5. Down comer system provided but not functional.
6. Fire pump provided but not functional.
7. Exit signage's are provided but not sufficient.
8. Fire/Smoke check door found damaged/defective at some locations.
9. Pressurization system found non-functional.

In view of the above, application for issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Elect), Delhi Electrical Div-41, CPWD, Andrews Ganj, New Delhi–110049