c/o 6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/EH/NDZ/2025/ 411 Dated: 24/10/2025

To

The Commissioner,
MCD, 9th floor, Civic Centre,
Minto Road, New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Cuisine And Cocktail located at M-20, M-Block, Greater Kailash, New Delhi.

Sir,

This has reference to the etl.mcdonline application no. 2025091813536 on the subject cited above. In this connection it is informed that the said restaurant was inspected by Assistant Divisional Officer (L.N) from this department on 06.10.2025 in the presence of Sh. Brijesh Yadav (Manager) and it was observed that the restaurant is running at 2nd floor & Terrace (Seating area) of the building which is comprised of Basement + Upper Ground + 02 upper floors. During the inspection the following shortcomings were observed:

1. Staircase & Door (exit) having width of 1.50 meters each found not provided.
2. Fire Check Door (FCD) found not provided.
3. Manually Operated Electrical Fire Alarm (MOEFA) System found not provided.
4. Main pump (2280LPM & head 50 m), Jockey pump (180 LPM Head 50 m) & Standby pump (2280LPM & head 50 m) found not provided.
5. Under Ground tank capacity of 1,00,000 liters found not provided.
6. Exit signages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

24/10/25
(A. K. Malik)
Dy. Chief Fire Officer(SZ)

o/c 24/10