C/30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/WZ/School/2026/584 Dated: -23/06/2026

To,

The Principal,
City Montessary School,
588/2, Pradhan Enclave Marg,
Burari, Delhi-110084.

Sub.: - Regarding renewal of Fire safety Certificate in r/o City Montessary School, located at 588/2, Pradhan Enclave Marg, Burari, Delhi-110084.

Sir,

This has reference to DFS online portal application no. 52026042702521 on the subject cited above, it is to inform you that the said building premises was re-inspected by the officer concerned of this department on 02/06/2026 in the presence of Sh. Rajesh Tomar (Principal). During inspection, it was observed that the building is comprised of ground + 02 upper floors and ground + 01 upper floor but school is running at old building i.e. ground + 02 upper floors & new block- ground floor only. After inspection, the following shortcoming were observed: -

1. 01 staircase required to be terminated at Terrace Level found removed.
2. First-Aid Hose Reel Hose found non-functional.
3. Fire Pump of 450 LPM found non-functional.
4. Overhead water storage tank could not be inspected in absence of inspection ladder.

In view of the above, the application for renewal of Fire Safety Certificate (FSC) cannot be considered at this stage and **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

22/06/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy: - For taking necessary action: -

1. The Commissioner, MCD, Dr. SPM Civic Centre, Minto Road, Delhi-110002.
2. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.