GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/Hosp/WZ/2026/ 154 Dated 28/04/2026

To,

The Authorized Signatory,
CK Birla Hospital,
57/41 West Punjabi Bagh,
New Delhi-110026.

Subject: - Regarding Surprise inspection in r/o CK Birla Hospital, Located at 57/41 West Punjabi Bagh, New Delhi-110026.

Sir,

As per directions of Competent Authority vide office F6/DFS/HQ/2026/494 dated 20.03.2026, on the subject cited above, in this connection, this is to inform you that the above mentioned hospital was visited by the officers concerned of this department on dated 16/04/2026 in the presence of Sh. Amit Sharma to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations : -

1. Staircase segregation found removed at ground floor.

You are advised to rectify the above mentioned shortcomings under intimation to this department, till the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the Owner/Occupier.

Yours faithfully,

28/04/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Center, New Delhi.
2. The Director General Health Service (DGEHS), Govt. of NCT of Delhi, F-17, Karkardooma, New Delhi-1100322.