GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2026/ 221 Dated: 05/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding issuance of Fire Safety Certificate in r/o M/s NOD located at Family Hall Ground floor, (Swimming Pool area) Punjabi Bagh Club, Ring Road, Delhi-110026.

Sir,

This has a reference to MCD application No. 2026050506379 dated 07/05/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 25/05/2026 in the presence of Mr. Dev (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. First-Aid-Hose Reel not provided.
2. Terrace fire pump of capacity 450 LPM not provided.
3. Overhead tank of 20,000 lit. not provided.
4. Exit Signage not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

04/06/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Dy. Health Officer, MCD, West Zone, Vihar Enclave, Rajouri Garden, New Delhi-110027. (dhowest zone@gmail.com)