C/191

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/EH/2025/ 486 Dated: 19 /12/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, New Delhi.

Sub: Regarding issuance of Fire Safety Certificate in r/o Clue Lounge and Bar at Plot No. 27, 3rd Floor, North West Avenue, Punjabi Bagh, New Delhi – 110027.

Sir,

This has reference to online application received through MCD online portal vide ID No. 2025112715211 dated 27/11/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officers concerned of this department on 02/12/2025 in presence of Sh. Narender Rana (Manager) to verify the compliance of shortcomings issued by this office vide letter No. F6/DFS/MS/EH/2025/WZ/303 dated 04/07/2025 (copy enclosed) and found that the shortcomings are not complied in totality.

In view of above, the application for issuance of fire safety certificate cannot be considered at this stage & stand **rejected**. Further, the occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Encl.: As above

18/12/25

(S. K. Dua)
Dy. Chief Fire Officer

OIC BP

Copy to:

1. The Manager, Clue Lounge and Bar at Plot No. 27, 3rd Floor, North West Avenue, Punjabi Bagh, New Delhi – 110027.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No: F.6/DFS/MS/EH//2025/WZ/303 Dated: 04/07/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st Floor,
Police Station, Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Clue Lounge & Bar (A Unit of Westernside Food Matrix Pvt. Ltd.) located at 27, 3rd Floor, NWA Club Road, West Punjabi Bagh, New Delhi- 110026.

Sir,

This has reference to online application received through MCD portal vide ID-2025051208349, on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 25.06.2025 in presence of Mr. Ranjan Mishra, Manager. Following shortcoming were observed at the time of inspection.

1. First aid hose reel found provided but not functional.
2. Detectors found provided but not functional.
3. MOEFA found provided but not functional.
4. Pumping system found provided but not functional.
5. Terrace level tank of 30,000 ltrs capacity found provided against the requirement of 50,000 ltrs.
6. Exit signage's found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)
Director
Ph. 011-23414000

Copy to:-

1. The owner/ occupier, M/s Clue Lounge & Bar. (A Unit of Westernside Food Matrix Pvt. Ltd.) located at 27, 3rd Floor, NWA, Club Road, West Punjabi Bagh, New Delhi-110026.
2. MCD Portal ID No. 2025051208349.