C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/847 Dated: 27/11/2025

To,

The Principal,
CM Shri School
Sec. 22, Dwarka, New Delhi- 110077

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o CM Shri School at Sec. 22, Dwarka, Delhi- 110077.

Sir,

Please refer to your letter No. SOE/DWK/25/288 dated 15.11.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 17.11.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Jaya Shree (Principal) was present and it was observed that the building comprised of ground plus three upper floors, and have following shortcomings:-

1. 04 no's hose reels found provided at each floor but found not functional.
2. Terrace level fire pump capacity of 450 LPM is found provided but not functional.
3. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

26/11/25

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.