GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/CNG/2025/SZ/ 632 Dated: 02/12/2025

FIRE SAFETY CERTIFICATE

Certified that the **CNG Filling Station** at DTC Depot, Keshopur Captive situated at Outer Ring Road, Delhi–110018, comprised of Ground floor only (01 dispenser), owned/occupied by M/s Indraprastha Gas Limited, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/CNG/2022/WZ/323 dated 22/07/2022. The premises was re-inspected by the officer concerned of this department on 29/10/2025 in the presence of Sh. Bijendra Singh (Manager) and observed addition of land and CNG filling facilities (04 dispenser, 01 Compressor and 01 Cascade) and found that the said premise have complied with the fire prevention and fire safety requirements in accordance with OISD-179 and fire safety guidelines issued vide letter No. 46 dated 04/02/2025 and that the premises is **fit for occupancy** class "**Hazardous Group–J**" (CNG Station) with effect from 02/12/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/12/**2025** at New Delhi by

1/12/25

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Joint Commissioner of Polie, Licensing Unit, First Floor, Police Station Defence Colony, New Delhi–110049
2. Sh. Ajay Khatri, GM (Fire & Safety), Indraprastha Gas Limited, IGL Bhawan, Plot No. 4, New Delhi 110021

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-8

INSPECTION REPORT				
1	Name & Address of the Building	CNG Hybrid Station, Keshopur, adjacent to Keshopur DTC Depot, Delhi-110018.		
2	Type of Occupancy	Hazardous Group 'J' (CNG Filling Station)		
3	Building Comprised of	Ground floor only. (04 Dispenser, 01 Cascade and one compressor)		
4	Type of Case	Addition/Alteration		
5	Details of Previous NOC	F.6/DFS/MS/CNG/2022/WZ/323 Dt. 22/07/2022		
6	Fire safety directives letter No	F.6/DFS/MS/BP/2025/46 dated 03/02/2025		
7	Date of Inspection	29/10/2025		
8	Name of the Inspecting Officers	ADO (JKP)		
9	Name & Designation of Officers from the building side	Sh. Bijendra Kumar (Manager)		
10	Year of construction	2025		
11	Applicant letter No.	IGL/F&S/2025/15/114/1 dated 14/10/2025 received through ODD No. Nil Dt. 15/10/25		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement As per directives	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	45 mtr	MR
	• Gate width	05 mtr	Accessible through open front	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➢ Upper floors.	N/A	N/A	N/A
	➢ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➢ Upper floors	N/A	N/A	N/A
	➢ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➢ Fire check door	N/A	N/A	N/A
	➢ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	Required	Provided	MR
	• Types	DCP/CO_2/ABC	DCP (9kg), CO_2, ABC & CO_2 (Trolley)	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A

N-9

7	Automatic fire detection & alarming system.	Gas & Flame	Provided in compressor	MR
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Control room	MR
	• Hooter's location	Required	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➢ Discharge of main pump.	N/A	N/A	N/A
	➢ Head of main pump.	N/A	N/A	N/A
	➢ Number of main pumps.	N/A	N/A	N/A
	➢ Jockey Pump output.	N/A	N/A	N/A
	➢ Jockey Pump head.	N/A	N/A	N/A
	➢ Standby Pump output.	N/A	N/A	N/A
	➢ Standby Pump head.	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➢ Pump house access.	N/A	N/A	N/A
	• Terrace Level			
	➢ Discharge of pump.	N/A	N/A	N/A
	➢ Head of pump.	N/A	N/A	N/A
	➢ Power supply.	N/A	N/A	N/A
	➢ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➢ Draw-off connection.	N/A	N/A	N/A
	➢ Fire Service Inlet.	N/A	N/A	N/A
	➢ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	Exit Signage/No Smoking Signage.	Required	In Hindi & English	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

D-10

19.	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of Special Risk, if any.	Required	Provided MCPs on min line, concealed electrical wiring, 04 fire bucket of dry loose sand.	MR

The fire protection systems such as fire extinguisher of different type & capacity, fire buckets filled with dry loose sand and water provided at suitable places in the retail outlet area were checked and found functional, "No Smoking sign board found displayed in Hindi & English at conspicuous locations. No loose electrical wiring seen in the premises at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/CNG/2022/WZ/323 dated 22/07/2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended**.

Accordingly, DFA is put up for approval & signature please.

5/11/25

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SW)

10/11/25

Dy. CFO (SZ) RAJINDER ATWAL

10/11/25
A.K. MALIK
Principal Director

'A' | OISD guidelines may be given as well as discuss

Dy. CFO (SZ)

20/11/25

DO (SW)

24/11/25
A.K. MALIK