GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/CNG/ 147 Dated: - 22/07/2026

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Rohini-II, DTC Bus Depot, Sector-16, Delhi-110089, comprised of Ground Floor only owned/occupied by Indraprastha Gas Limited, was issued Fire Safety Certificate by this department Vide Letter No. F.6/DFS/MS/2021/CNG/152 dated 05/03/2023. The said premise was re-inspected by the officer concerned of this department on 29/06/2026 in the presence of Sh. Rajnish Kumar Pandey, (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Hazardous Building" Group - J with effect from 22/07/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 22/07/2026 at New Delhi by.

21/07/26
(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Ajay Khatri, DGM (Fire & Safety), IGL Bhawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building	CNG Station at Rohini-II, DTC Bus Depot, Sector-16, Delhi-110085
2. Type of Occupancy	Hazardous "Group- J"
3. Type of Case	Renewal
4. Composition of building	Ground Floor only
5. Details of Previous NOC	F.6/DFS/MS/2021/CNG/152 dated 05/03/2023
6. Fire Safety directives letter No	F.6/DFS/MS/CNG/2019/7553 dated 18/12/2019
7. Date of inspection	29/06/2026
8. Name of Inspecting Officer	Paras Kumar, ADO (Rohini)
9. Name and designation of officers From the building side	Sh. Rajnish Kumar Pandey (Manager)
10. Year of Construction	
11. Applicant's letter no.	IGL/F&S/2026/15/123/1 dated 15/06/2026

S. No	Minimum Standards on fire prevention and fire safety U/R 33	OISD/Directive Requirements	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	Required	45 m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0 m	Provided	MR
3.	**Compartmentation**			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	a) Basements	NA	NA	NA
	b) Ground floor	NA	NA	NA

5.	**Fire Extinguishers**			
	a) Total numbers	75 kg-02 DCP 10 kg-08 DCP 4.5 kg-04 CO_2	Provided	MR
	b) Types	ABC/CO2	Provided	MR
	c) IS marking	ISI marked	Provided	MR
6.	**First-Aid Hose Reels**			
	a) Total numbers on each floor	NA	NA	NA
	b) Length of hose reel hose	NA	NA	NA
	c) Nozzle diameter	NA	NA	NA
7.	**Automatic fire detection and alarming system**			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	NA	NA	NA
10.	**Automatic Sprinkler System**			
	a) Basement	NA	NA	NA
	b) Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	**Internal Hydrants**			
	a) Size of riser/down-comer	NA	NA	NA
	b) Number of hydrants per floor	NA	NA	NA
	c) Hose Box	NA	NA	NA
12.	**Yard Hydrants**			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey Pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual Stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	Terrace level			
	➢ Discharge of pump	NA	NA	NA
	➢ Head of the pump	NA	NA	NA
	➢ Power Supply	NA	NA	NA
	➢ Auto Starting of pump	NA	NA	NA
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

	Exit Signage.	NA	NA	NA
	Provision of Lifts.			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	**Standby power supply**	NA	NA	NA
18.	**Refuge Area.**			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	**Fire Control Room**			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	Required	Fire buckets filed with sand, No Smoking board were found displayed in Hindi & English. No lose electric wiring were seen in premises & CO_2 flooding system found provided, gas cascade protected with water mist spray	MR

The fire protection systems provided in the building were checked and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety required under the rules, the FSC issued vide letter no. F.6/DFS/MS/2021/CNG/152 dated 05/03/2023 renewal under rule 37 of the Delhi Fire Service Rule 2010 **is recommended**.

30/06/2026

Signature of the Inspecting Officer
Name : - Paras Kumar
Designation : - ADO (Rohini)

DO/N/W 1/7

Dy CFO/WZ 08/07/2026

CFO (WZ) 08/07/26

Pr. Director 8/7

CFO (WZ)

F.T. please 16/07/26

ADO(Rohini)